



Har Ghar Jal
Jal Jeevan Mission

ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ ਜ/ਸ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਮੰਡਲ-1 ਬਟਾਲਾ।

Tele/fax: 01871-500294

e-mail: ewssbatala@yahoo.com

ਸੇਵਾ ਵਿਖੇ,

ਜਿਲ੍ਹਾ ਸਿਖਿਆ ਅਫਸਰ,
ਗੁਰਦਾਸਪੁਰ।


ਨੰ: ੪੫੫

ਮਿਤੀ: ੫-6-25

ਵਿਸ਼ਾ ਜਨ ਸਿਹਤ ਸੇਵਾਵਾਂ ਸਬੰਧੀ ਸਰਟੀਫਿਕੇਟ ਜਾਰੀ ਕਰਨ ਬਾਰੇ।

ਹਵਾਲਾ ਆਪ ਦੇ ਦਫਤਰ ਦਾ ਪੱਤਰ ਨੰ: ਜੀ.3/2025 5091 ਮਿਤੀ 18.03.2025


ਉਕਤ ਵਿਸ਼ੇ ਅਤੇ ਹਵਾਲੇ ਅਧੀਨ ਪੱਤਰ ਦੇ ਸਬੰਧ ਵਿਚ **LAURENS INTERNATIONAL SCHOOL, DALLA MORR, QADIAN, DISTRICT GURDASPUR** ਵਿਖੇ ਜਨ ਸਿਹਤ ਸੇਵਾਵਾਂ ਦੀ ਪ੍ਰੋਵੀਜ਼ਨ ਤਸੱਲੀ ਬੱਖਸ਼ ਪਾਈ ਗਈ ਹੈ। ਜਨ ਸਿਹਤ ਸੇਵਾਵਾਂ ਦਾ ਸਰਟੀਫਿਕੇਟ 31.03.2026 ਤੱਕ ਇਸ ਸ਼ਰਤ ਤੇ ਜਾਰੀ ਕੀਤਾ ਜਾਂਦਾ ਹੈ ਕਿ ਜੇਕਰ ਇਸ ਸਮੇਂ ਦੌਰਾਨ ਮੁੜ ਚੈਕਿੰਗ ਕਰਨ ਤੇ ਜਨ ਸਿਹਤ ਸੇਵਾਵਾਂ ਵਿਚੋਂ ਕੋਈ ਕਮੀ ਪੇਸ਼ੀ ਪਾਈ ਗਈ ਤਾਂ ਇਸ ਸਰਟੀਫਿਕੇਟ ਰੱਦ ਕਰਨ ਦਾ ਹੱਕ ਮਹਿਕਮੇ ਵੱਲੋਂ ਰਾਖਵਾਂ ਹੋਵੇਗਾ।


ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ,
ਜ/ਸ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਮੰਡਲ-1,
ਬਟਾਲਾ।

ਪਿਠ ਅੰਕਣ ਨੰ:

ਮਿਤੀ:

ਉਪਰੋਕਤ ਦੀ ਨਕਲ **LAURENS INTERNATIONAL SCHOOL, DALLA MORR, QADIAN, DISTRICT GURDASPUR** ਨੂੰ ਸੂਚਨਾਂ ਹਿੱਤ ਭੇਜੀ ਜਾਂਦੀ ਹੈ।


ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ,
ਜ/ਸ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਮੰਡਲ-1,
ਬਟਾਲਾ।

REGIONAL WATER TESTING LAB, AMRITSAR
New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.
rwtlasr1@gmail.com

To,

SDE Water Supply and Sanitation Sub Division No.1 Batala
SDE Water Supply and Sanitation Sub Division No.1 Batala

No.: RWTLASR/2526/00132 Dated : 19/05/2025

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 235 Dated: 30/04/2025

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 02/05/2025. It is request to fill the attached feedback form and send it back to Regional Water Testing Lab, Amritsar

D/A : Test Report



Authorized Signatory
For, Regional Water Testing Lab
Amritsar

REGIONAL WATER TESTING LAB, AMRITSAR
New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.
rwtlasr1@gmail.com

TEST REPORT						
Name & Address of Customer : SDE Water Supply and Sanitation Sub Division No.1 Batala SDE Water Supply and Sanitation Sub Division No.1 Batala			Customer Reference No.		No : 235 Dated : 30/04/2025	
			Sample Submitted by		Mr.Balwinder Singh	
			Date of Sample Receipt		02/05/2025	
			Analysis Starting Date		06/05/2025	
			Analysis completion Date		06/05/2025	
Discipline : Chemical Testing			Group: Water			
ULR No.:				Sample Type :		Water
Test Report No.:		RWTLASR/2526/00132		Date of Issue :		19/05/2025
Registration no.:		RWTLASR/REG2526/00677		Condition of Sample :		Sealed
Collection Point:		Private Submersible		Quantity/Type of Bottle:		500 ml / Amber Colored Glass Bottle
Scheme/Source:		Not Mentioned(Not Mentioned)		Location/Depth :		Laurens International School Dalla More Qadian (Tubewell 79 mtr) / NA
Village :		Not Mentioned		Habitation :		Not Mentioned
Block:		Not Mentioned		District :		Gurdaspur
Latitude :		Not Mentioned		Longitude:		Not Mentioned
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	Aluminium(Al)	0.029	0.03	0.2	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
2	Lead	BDL(0.005)	0.01	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
3	Selenium	BDL(0.005)	0.01	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
4	Chromium(Cr)	BDL(0.005)	0.05	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
5	Mercury	BDL(0.0005)	0.001	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
6	Arsenic(As)	BDL(0.005)	0.01	No relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
7	Cadmium(Cd)	BDL(0.001)	0.003	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
8	Nickel	BDL(0.005)	0.02	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
9	Iron(Fe)	0.042	1	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
10	Copper(Cu)	0.015	0.05	1.5	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
11	Uranium	2.374	30	No Relaxation	µg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't beused be as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By



Mr. Pardeep kumar
Quality Manager
Authorized Signatory
For,Regional Water Testing Lab
Amritsar

----- End of the Test Report -----